



## PART THREE-RISK ASSESSMENT

Ravenscroft Road  
Moor Pool Estate  
Harborne  
Birmingham

## Detailed sequence of work task or activity

1. All Operatives to be inducted by Site Manager including this risk assessment, method statement, asbestos survey and any information from assessments regarding manual handling.
2. All Operatives to be issued with P.P.E in accordance with company procedure relevant to their task.
3. Telehandler fork truck/plant and waste deliveries to keep clear of box culvert, (See attached traffic management plan.)
4. No work will be carried out where there is danger from live services until confirmation is obtained that services have been terminated or isolated and protected.
5. Asbestos coveralls, masks & gloves must be removed at break times and operatives to practice good hygiene i.e. wash hands and face before entering canteen. **Coveralls gloves and masks to be disposed of as asbestos waste at the end of each working shift.**
6. In order to minimise exposure and control the spread of asbestos, materials should be damped down using water or P.V.A solution. Dry sweeping of debris that contains asbestos materials should also be avoided.
7. Operatives will gain access to height by erecting podium steps, Operatives will start at end of garage where sheets over lap. Once at height operatives will spray area of roof sheets to be removed using a pva/water solution. Using bolt crops operatives will shear through down hold bolts attaching them to light weight steel frame.
8. Operatives will lift roof sheets allowing them to free them selves, once free operatives will slide sheets down to operative on ground floor, theses will then be placed onto telehandler forks then carted and placed into asbestos waste skip positioned close to working area.
9. Any broken pieces will be picked and placed into asbestos grade bags, ceiled and placed into asbestos skip.
10. Banksman to be in attendance at all times during work operations.

**NOTE ALL METHOD STATEMENTS ARE SUBJECT TO CHANGE IF YOU SUSPECT PRACTICAL WORKING METHODS ARE VARYING FROM METHOD STATEMENT CEASE WORKS AND ALERT YOUR SUPERVISOR.**

Produced By:	D Woodall	Checked By:	C Denning
Signature:		Signature:	
Date:	16.06.12.	Date:	15/06/12

To be completed by foreman/ supervisor in control of the task/ activity:

I have read, understood and will comply with this safe system of work, and ensure all operatives follow suit.